

**APPENDIX - VIII**

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. 1012

Date : 26.2.2026

It is certified that an inspection team headed by Surender Kumar Sharma  
Junior Chemist (Name of Officers  
with designation) from PHED Laboratory Jhunjhunu (Name of  
Department/Office) inspected the Vedic Valley High School, Nawalgarh  
Jhunjhunu (Raj.) (Name & Address of  
the School) on \_\_\_\_\_ and found that the Vedic Valley High School  
Nawalgarh, Jhunjhunu (Raj.) (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central/State/U.T Govt.

The above valid for a period of One Year.

Signature with Seal :

(सुरेन्द्र कुमार शर्मा)

कनिष्ठ रसायनज्ञ

Name

जन स्वा० अग्नि० विभाग  
प्रयोगशाला झुझुनू

Designation

:

To

Vedic Valley High School

Nawalgarh, Jhunjhunu (Raj.)

(Name & Address of the Institution)

MANAGER  
Vedic Valley High School  
Nawalgarh

Principal  
Vedic Valley High School  
Nawalgarh



**PUBLIC HEALTH ENGINEERING DEPARTMENT  
LABORATORY JHUNJHUNU**

**CHEMICAL EXAMINATION REPORT OF WATER**

No. Lab. / Chem. /2025-26/ 1012

Date - 26.2.2026

To,  
Vadic Valley High School  
Nawalgarh

District - Jhunjhunu

Tehsil:- Nawalgarh

Ref- Your letter dated 24.02.26

Date of Exam – 25.02.26

| A      | Name & Location of Source                    | IS-10500:2012    |                    | Water Sample<br>Vadic Valley High School |
|--------|----------------------------------------------|------------------|--------------------|------------------------------------------|
| B      | Village/ Town                                |                  |                    | Nawalgarh                                |
| C      | Date Of Collection                           |                  |                    | 24.02.26                                 |
| D      | Lab. Sample No.                              |                  |                    | C-186                                    |
| Sr. No | Parameters                                   | Desirable limits | Permissible limits | Value                                    |
| 1      | pH                                           | 6.5—8.5          | 6.5—8.5            | 8.17                                     |
| 2      | Turbidity[NTU]                               | 1                | 5                  | Nil                                      |
| 3      | Temperature[C]                               | -----            | -----              | 25                                       |
| 4      | Colour[Units]                                | 5 Hazen Unit     | 15 Hazen Unit      | None                                     |
| 5      | Odour                                        | Unobjectionable  | Unobjectionable    | Unobj.                                   |
| 6      | Residual Chlorine                            | 0.2              | 1.0                | Nil                                      |
| 7      | Total Alkalinity[asCaCO <sub>3</sub> ]       | 200              | 600                | 430                                      |
| 8      | Total Hardness[asCaCO <sub>3</sub> ]         | 200              | 600                | 200                                      |
| 9      | Chloride[asCl <sup>-</sup> ]                 | 250              | 1000               | 240                                      |
| 10     | Nitrate[as NO <sub>3</sub> <sup>-</sup> ]    | 45               | 45                 | 43                                       |
| 11     | Fluoride [as F <sup>-</sup> ]                | 1.0              | 1.5                | 0.65                                     |
| 12     | Sulphate [as SO <sub>4</sub> <sup>-2</sup> ] | 200              | 400                | 32                                       |
| 13     | TDS                                          | 500              | 2000               | 1038                                     |

Note:1- All Results Except pH in mg/L.

2- This report is not valid for legal cases/legal purposes.

**Principal  
Vedic Valley High School  
Nawalgarh**

**(S K Sharma)  
Junior Chemist  
PHED Laboratory Jhunjhunu**

**MANAGER  
Vedic Valley High School  
Nawalgarh**